

<u>Surry Downs: PCB Sampling</u>		<u>Cleanup Standard For High Occupancy Area is 1 ppm (Porous Surfaces): 10µg/100cm² for Non-Porous Surfaces</u>	
<u>Date: August 5, 2004</u>	Location	Analytical Data	Remarks
Sample 043224050	Main Office: Center Fixture	81µg/100cm ²	Wipe Sample from Fixture (East End)
Sample 043224051	Main Office: Center Fixture	390µg/100cm ²	Wipe Sample from Fixture (West End)
Sample 04324052	Preschool #3: Center Fixture: Near Entry Door	460,000 µg/100cm ²	Wipe Sample from Tray (East End)
Sample 0432053	Preschool #3: Center Fixture: Entry Door East Side	140,000 µg/100cm ²	Wipe Sample from Fixture (West End)
Sample 0432054	Preschool #4: Rear Room West Side of Building	310µg/100cm ²	Wipe Sample from Bottom of Tub (Southwest Corner of Rear Room)
<u>August 10, 2004</u>			
Sample 04334301	After School Area: Back Room #1 North side of Room	~ 40 µg/100cm ²	Wipe Sample of Fixture (West End)
Sample 04334302	After School Area: Back Room #1 Southwest side of Room	96,000µg/100cm ²	Wipe Sample of Fixture (West End)
Sample 04334303	After School Area: Back Room #1 Southeast side of Room	47 µg/100cm ²	Wipe Sample of Fixture (West End)
Sample 04334304	After School Area: Center Room #2 Northside of Room	920 µg/100cm ²	Wipe Sample of Fixture (West End)

Sample 04334305	After School Area: Center Room #2 North Section of Room	~ 40 µg/100cm ²	Wipe Sample of Ceiling Beam
Sample 04334306	After School Area: Center Room #2 Back Room #1	58 µg/100cm ²	Wipe Sample of Fixture; Advance Ballast
Sample 04334307	Pre Kindergarten/ Kindergarten Room Back Room #1 Sink Area	1100 µg/100cm ²	Wipe Sample of Double Fixture
Sample 04334308	Pre Kindergarten/ Kindergarten Room Back Room #1 South edge of room	390,000 µg/100cm ²	Wipe Sample of Middle Fixture
Sample 04334309	Pre Kindergarten/ Kindergarten Room Back Room #1 Northeast corner	210 µg/100cm ²	Wipe Sample of Fixture
Sample 04334310	Pre Kindergarten/ Kindergarten Room Back Room #2 North wall fixture	1,500,000 µg/100cm ²	Wipe Sample of Fixture
Sample 04334311	Pre School 4 Area Back Room #1 North Wall fixture	3,300,000 µg/100cm ²	Wipe Sample of Fixture
Sample 04334312	Pre School 4 Area Back Room #1 Southwest Corner	1,700,000µg/100cm ²	Wipe Sample of Fixture
Sample 04334313	Pre School 4 Area Back Room #1 Carpet Stain below First Double Fixture Southwest Corner	92 µg/100cm ²	Wipe Sample of Carpet Stain